

Reporting times

Here's how our products stack up against industry standards.

BT Redcare portfolio	Essential IP/ Essential					Essential Extra/ Advanced					Essential Extra/ Advanced					Essential IP				Advanced Extra/ Classic & GSM replacement				Ultimate			
	A	B	C	A	B	C	D	E	F	A	B	B	C	C	D	E	A	B	C	D							
Alarm Transmission System (ATS) Standard (EN & PD6669)	Optional	Optional	SP1	SP2	SP2	DP1	SP3	Optional	DP2	SP3	SP3	SP3+	DP2	DP2+	SP4	DP3	SP5	SP5	DP4	SP6							
Remotely powered audible warning device	2	Optional	Optional	2	Optional	Optional	Optional	Optional	Optional	2	Optional	Optional	Optional	Optional	Optional	Optional	2	Optional	Optional	Optional							
Self powered audible warning device	Optional	1	Optional	Optional	1	Optional	Optional	1	Optional	Optional	1	1	Optional	Optional	Optional	Optional	Optional	1	Optional	Optional							
Primary Alarm Transmission Path (ATP) reporting time	Optional	Optional	32 days	60 mins 25 hours	60 mins 25 hours	25 hours	30 mins	Optional	30 mins	30 mins	30 mins	10 mins	30 mins	10 mins	3 mins	3 mins	90 secs	90secs	90secs	20 secs							
Alternate ATP maximum period when primary operational	Optional	Optional	Optional	Optional	Optional	50 hours	Optional	Optional	5 hours 25 hours	Optional	Optional	Optional	5 hours 25 hours	25 hours	Optional	60 mins 25 hours	Optional	Optional	60 mins 5 hours	Optional							
Alternate ATP maximum period when primary failed	Optional	Optional	Optional	Optional	Optional	25 hours	Optional	Optional	30 mins	Optional	Optional	Optional	30 mins	10 mins	Optional	3 mins	Optional	Optional	90secs	Optional							
Catastrophic failure	Optional	Optional	32 days	60 mins 25 hours	60 mins 25 hours	25 hours	30 mins	Optional	31 mins	30 mins	30 mins	10 mins	31 mins	11 mins	3 mins	4 mins	90 secs	90secs	3 mins	20 secs							
Previous grading standard (pre-June 2019)	Grade 1			Grade 2				Grade 3					Grade 4														
Current grading standard	Grade 1			Grade 2						Grade 3						Grade 4											

Key: **BT Redcare** Standards minimum requirement



EN 50136-2:2013
EN 50131-10:2014
Cert No. 1270g



Police Preferred Specification

redcare.bt.com

